

Environ Tech Laboratories

NABL Accredited/MoEF & CC Recognized/PPCB Approved/ OHSAS 18001: 2007 Certified

Plot No.62, Janta Industrial Estate,
Airport Road, Sector 82, S.A.S. Nagar
(Mohali)-160062 Punjab
Mob. 9417210081, 9417220081
9464000081, Tel. 9463000081

GSTIN : 03BPEPS9693P1ZV
PAN No. BPEPS9693P

Page 1 of 1

Dispatch No: ETL/DSP/2019/191144

Date: 27/08/2019

TEST REPORT

To
M/s Kuantum Papers Ltd,
Saila Khurd, Distt Hoshiarpur, Punjab

Report No.	ETL/44/2019-20/G/191206	Report Date	27.08.2019
Your Ref. No.	Nil	Type of sample	Treated Water Sample
Sample Code Given by Customer	Nil	Quantity	2 LITER
		Date of Sampling	24.08.2019
Sampling Location	Within Premises	Date of sample receipt	24.08.2019
Sample Collected By	Lab Person	Sample I.D.	ETL/32/2019-20/G/1206
Sampling procedure	As per SOP	Date of test	24.08.2019 - 27.08.2019

S. NO.	PARAMETERS	TEST RESULTS	STANDARDS EPA(RULES) 1986-SCHEDULE-6			TEST METHODS
			Inland surface Water	Public Sewer	Land for Irrigation	
1	pH	7.18	5.5 - 9.0	5.5 - 9.0	5.5 - 9.0	IS:3025,(Part-11)2002, Reaff. 2017. APHA 23 rd Edition:2017-4500 H+ B
2	Total Suspended Solids, mg/L	43	100	600	200	IS:3025,(Part-17)2012, Reaff. 2017. APHA 23 rd Edition:2017-2540 D
3.	Total Dissolved Solid, mg/l	1566	--	--	--	IS:3025(Part-16)2006, Reaff. 2017. APHA 23 rd Edition:2017-2540 C
4	Bio-chemical Oxygen Demand at 27°C 3 days, mg/L	22	30	350	100	IS:3025,(Part-44):2009, Reaff. 2014. APHA 23 rd Edition:2017 - 5210 B
5	Chemical Oxygen Demand, mg/L	192	250	No guideline	No guideline	IS:3025,(Part-58)2006, Reaff. - 2017. APHA 23 rd Edition:2017-5220 B
6	AOX	4.64	--	--	--	LAB SOP
7	Sodium Absorption Ratio	2.38	--	--	--	By Calculation

Note:

1. The test report refers only to tested sample and applicable parameters.
2. This report can neither be used as evidence in the court of law nor can it be used in part or full in any media without prior permission.
3. The sample will be destroyed after thirty days from the date of issue of test report unless otherwise specified.

(Checked By)

(Authorized Signatory)

****End of Report****

Testing of Water, Waste Water, Soil, Food, Ambient Air, Noise Monitoring & Stack Emission

Email : envirotechlab72@yahoo.com, director@envirotechlab.in | Website : envirotechlab.com

NOT VALID FOR LEGAL PURPOSES